

SUBSTATION :-

220/33kV SUBSTATION

TITLE:-

BUSBAR DESIGN CALCULATION

SAMPLE DOCUMENT

BUSBAR DESIGN CALCULATION

1.0 SYSTEM DATA-220kV		220kV S/S		Unit	
1.1	Highest System Voltage	V	-	245	kV
1.2	Short circuit current	I _{sc}	-	40000	Amps
1.3	Duration of Fault	t	-	1	sec
1.4	Factor of Peak short circuit current	κ	-	1.81	
1.5	System frequency	f	-	50	HZ
1.6	Design Ambient Temperature	T	-	50	°C
1.7 a)	Centre Line distance between conductors for Strung bus	a	-	4.5	m
b)	Centre Line distance between conductors for Equipment bus	a	-	4	m
1.8	Wind Pressure on conductor (Ref. Annexure-1)	P	-	148.002	Kg/m ² (Refer. Annexure-1)
1.9	Maximum distance between two supporting points for 4" EH IPS Al.Tube.	L	-	8.05	m
1.10	Line to ground distance of 4"EH IPS Al Tube.	-	-	6	m
1.11	Line to ground distance of "TWIN MOOSE ACSR".	-	-	6/11.7/16.7/26.2	m

2.0 BUSBAR DATA:-

		STRUNG BUS	BETWEEN EQPTS SCHEDULE 80			
		MOOSE ACSR	4" EH IPS Al. Tube			
2.1	Busbar Used					
2.2	Outer diameter	Do	-	31.77	114.3	mm
2.3	Inner diameter	Di	-	---	97.18	mm
2.4	Area of Cross - section	A	-	528.5	2844	mm ²
2.5	Moment of Inertia	J	-	---	399.998	cm ⁴
2.6	Weight per unit length of conductor	m'	-	1.999	7.678	Kg/m
2.7	Section modulus	Z	-	---	69.989	cm ³
2.8	Young's modulus	E	-	6.9000E+10	6.5727E+10	N/m ²
2.9	Yield point	R _{p0.2}	-	---	161.865	N/mm ²
2.10	Ultimate Bending stress of Al.Alloy		-	---	201.105	N/mm ²
2.11	Initial temp.of busbar before short circuit	θ _i	-	75	85	°C
2.12	Final temp.of busbar before short circuit	θ _f	-	200	200	°C

3.0 REFERENCES:-

- 1 IEC 865 - Short circuit currents - Calculation of effects.
- 2 IEC 909 - Short circuit current calculations in three phase AC systems
- 3 Indal Aluminium busbars book.
- 4 IS:802-Code of practice for Use of structural steel in overhead transmission line towers.
- 5 Electra-68-1980

CALCULATION FOR 220kV S/S:-**1.0 CHECK FOR MAX. CONTINUOUS CURRENT CARRYING CAPACITY OF ' MOOSE ' ACSR CONDUCTOR:**

Conductor used	=	TWIN Moose ACSR for Main Bus I & Main Bus II
Continuous current rating of " Single Moose ACSR " at 75°C	=	836 Amps (As per diamond cables catalogue page no:79)
Hence current carrying capacity of "TWIN MOOSE ACSR"	=	1672 Amps
Full load current on the 220kV side of 10MVA Trf.(3φ)	=	$10 \times 10^6 / (\sqrt{3} \times 220 \times 10^3)$
	=	26.2 Amps
Total current on Main bus,Considering 2 Nos of 3φ Transformers.	=	2X26.2
	=	52.5 Amps

Hence "TWIN MOOSE ACSR" for main bus is adequate

2.0 CHECK FOR SHORT TIME RATING OF MOOSE ACSR:

- 1) Conductor Temperature at the beginning of a short circuit θ_b = 75°C
- 2) Conductor Temperature at the end of a short circuit θ_e = 200°C (As per table 6 of IEC 865-1)
- 3) Rated short time withstand current density for 1sec. S_{th} = 82 Amp/mm² (As per Fig 13 of IEC-865-1)
- 4) Hence short time withstand rating of MOOSE ACSR = 82 x 528.5 = 43337 Amps
- 5) Short Circuit Rating of 220KV System = 40000 Amps

HENCE SAFE

3.0 CHECK FOR SHORT TIME RATING OF AL.TUBE:

Required area of cross-section of AL.Tube(A)

$$A = \frac{I_{sc} \times \sqrt{t}}{2.17 \times 10^4 \times \sqrt{\log\{\theta_f + 258/\theta_i + 258\}}}$$

As per INDAL AL. busbar Book.

Where

A - Required area of Aluminium conductor in cm²

I_{sc} - Symmetrical short circuit currents in Amps

t - Duration of fault in seconds

θ_i - Initial temperature before short circuit in °C

θ_f - Final temperature after short circuit in °C

$$A = \frac{40000 \times \sqrt{1}}{2.17 \times 10000 \times \sqrt{\log\{(200+258)/(85+258)\}}}$$

A = 5.2018 cm²

A = 520.18 mm²

Area of cross - section of selected busbar.

a) 4" IPS AL.Tube (SCH.80) = 2844 mm²

HENCE SAFE

4.0 CHECK FOR CONTINUOUS CURRENT RATING OF AL. TUBE:

Busbar used	=	4" EH IPS Al. Tube (SCH.80)
Current carrying capacity of 4" EH IPS Al. Tube for Temp. rise of 50 Deg.C over an ambient of 35 Deg.C	=	3590 Amps (As per INDAL AL. busbar Book.)
Correction Factor for temp. raise of 35 Deg.C over an ambient of 50 Dec.C	=	0.815 (As per Table 5 of INDAL AL BUSBAR BOOK)
Continuous current rating of Al. Tube for 35 Deg.C temperature rise over 50 Deg.C Ambient.	=	3590 x 0.815
	=	2925.85 Amps
Max. Bus Bar Rating	=	1600 Amps

Hence 4" EH IPS Al.Tube is adequate.

5.0 CHECK FOR VOLTAGE GRADIENT:-**5.1 Average voltage gradient at the surface of the bundled conductors**

$$E_a = \frac{V}{n \times r \times \ln(2 \times h_e / r_e)} \quad \text{kV/cm}$$

Where,

$$r_e = r \times [k \times s / r]^{n-1/n} \quad \text{cm}$$

$$h_e = \frac{h \times d}{\sqrt{[(2h)^2 + d^2]}} \quad \text{cm}$$

Where,

V - Highest line to ground voltage in kV
- 141.5 kV

n - No. of conductors in the bundles
2 for twin conductors
1 for Single conductors

r - radius of the individual conductor in cm
- $3.177 / 2 = 1.5885 \text{ cm}$ (Moose ACSR)

k - constant
- $11.43 / 2 = 5.715 \text{ cm}$ (4" EH IPS Al. Tube)

s - Sub conductor spacing in the bundle in cm

h - Line to ground distance in cm.
- 600 cm For Equipment Bus
- 1170 cm For Main Bus
- 1670 cm For Main Bus
- 2620 cm For Jack Bus

d - Phase to phase spacing in cm.
- 400 cm For Equipment Bus
- 450 cm For Strung bus

re - Equivalent single conductors of bundled conductors in cm

he - Equivalent single phase line to ground distance of a three phase system in cm

5.2 Equivalent single conductors of bundled conductors(re)**ForTwin Moose ACSR(Main Bus) conductor**

$$r_e = 1.5885 \times \left[\frac{[1 \times 25]}{1.5885} \right]^{[2 - 1] / 2}$$

$$= 6.3 \text{ cm}$$

5.3 Equivalent single phase line to ground distance of a three phase system (he)**a) For 4"EH IPS Al.tube bus at 6.00 m level**

$$h_e = \frac{600 \times 400}{\sqrt{[(2 \times 600) \times (2 \times 600)] + [400 \times 400]}}$$

$$= 189.74 \text{ cm}$$

b) For TWIN MOOSE ACSR at 6.0 m level

$$h_e = \frac{600 \times 400}{\sqrt{[(2 \times 600) \times (2 \times 600)] + [400 \times 400]}}$$

$$= 189.74 \text{ cm}$$

c) For TWIN MOOSE ACSR at 11.7 m level

$$h_e = \frac{1170 \times 450}{\sqrt{[(2 \times 1170) \times (2 \times 1170)] + [450 \times 450]}}$$

$$= 220.95 \text{ cm}$$

d) For TWIN MOOSE ACSR at 16.7 m level

$$h_e = \frac{1670 \times 450}{\sqrt{[(2 \times 1670) \times (2 \times 1670)] + [450 \times 450]}}$$

$$= 222.99 \text{ cm}$$

e) For TWIN MOOSE ACSR at 26.2 m level

$$h_e = \frac{2620 \times 450}{\sqrt{[(2 \times 2620) \times (2 \times 2620)] + [450 \times 450]}}$$

$$= 224.17 \text{ cm}$$

5.4 Average voltage gradient at the surface of the bundled conductors (Ea) / 4"EH IPS Al.Tube :

a) For 4"EH IPS Al tube at 6.00 m level

$$E_a = \frac{141.5}{1 \times 5.715 \times \ln \left(\frac{2 \times 189.74}{5.715} \right)} \text{ kV/cm}$$

$$= \mathbf{5.9 \text{ kV/cm}}$$

b) For TWIN Moose ACSR conductor at 6.0 m level

$$E_a = \frac{141.5}{2 \times 1.5885 \times \ln \left(\frac{2 \times 189.74}{6.3} \right)} \text{ kV/cm}$$

$$= \mathbf{10.87 \text{ kV/cm}}$$

c) For TWIN Moose ACSR conductor at 11.7 m level

$$E_a = \frac{141.5}{2 \times 1.5885 \times \ln \left(\frac{2 \times 220.95}{6.3} \right)} \text{ kV/cm}$$

$$= \mathbf{10.48 \text{ kV/cm}}$$

d) For TWIN Moose ACSR conductor at 16.7 m level

$$E_a = \frac{141.5}{2 \times 1.5885 \times \ln \left(\frac{2 \times 222.99}{6.3} \right)} \text{ kV/cm}$$

$$= \mathbf{10.46 \text{ kV/cm}}$$

e) For TWIN Moose ACSR conductor at 26.2 m level

$$E_a = \frac{141.5}{2 \times 1.5885 \times \ln \left(\frac{2 \times 224.17}{6.3} \right)} \text{ kV/cm}$$

$$= \mathbf{10.44 \text{ kV/cm}}$$

Allowable voltage gradient at the surface of the conductor is **20kV/cm.**

HENCE SAFE

5.5 Average voltage gradient at the surface of the Single conductors

$$E_a = \frac{V}{r \times \ln(2 \times h / r)} \text{ kV/cm}$$

Where,

- V - Highest line to ground voltage in kV
- 141.5 kV
- r - Radius of conductor in cm.
- 1.5885 cm.
- h - Line to ground distance in cm.
- 2620 cm (For Strung bus)
- 600 cm (For Equipment bus)

a) For Single Moose ACSR conductor at 26.2 m level

$$E_a = \frac{141.5}{1.5885 \times \ln \left(\frac{2 \times 2620}{1.5885} \right)} \text{ kV/cm}$$

$$= \mathbf{11 \text{ kV/cm}}$$

b) For Single Moose ACSR conductor at 6.0 m level

$$E_a = \frac{141.5}{1.5885 \times \ln \left(\frac{2 \times 600}{1.5885} \right)} \text{ kV/cm}$$

$$= \mathbf{13 \text{ kV/cm}}$$

Allowable voltage gradient at the surface of the conductor is **20kV/cm.**

HENCE SAFE

6.0 CALCULATION FOR FIBRE STRESSES ON TUBULAR BUSBAR(4" EH IPS .SCH:80):-**6.1 CALCULATION FOR MAXIMUM SPAN WITH ONE END RIGID AND OTHER END SIMPLY SUPPORTED****6.1.1 Maximum force acting on the central conductor during 3 phase short circuit (F_{m3}) is**

$$F_{m3} = \frac{0.2 \times 0.87 \times i_{p3}^2 \times L}{a} \quad \text{N}$$

Where

 i_{p3}^2 = Peak short circuit current in kA

$$= \frac{I_{sc} \times 1.81 \times \sqrt{2}}{1000}$$

$$= \mathbf{102.0 \text{ kA}}$$

Therefore,

$$F_{m3} = \frac{0.2 \times 0.87 \times 102 \times 102 \times 8.05}{4} \quad \text{N}$$

$$= \mathbf{3643 \text{ N}}$$

6.1.2 Natural frequency of the tubular busbar of a single conductor

$$f_c = \frac{\gamma}{L^2} \times \sqrt{\frac{E \times J}{m'}} \quad \text{HZ}$$

Where

 γ = Factor of natural frequency estimation

$$= \mathbf{2.45} \text{ (From table -III of IEC 865-1)}$$

 β = Factor for main conductor stress

$$= \mathbf{0.73} \text{ (From table -II of IEC 865-1)}$$

 E = Young's modulus of Al.tube in N/m²

$$= \mathbf{6572700000 \text{ N/m}^2}$$

 J = Moment of Inertia in m⁴

$$= \mathbf{0.0000399998 \text{ M}^4}$$

 m' = mass per unit length of conductor in Kg/m

$$= \mathbf{7.678 \text{ Kg/m}}$$

 L = Distance between two supporting points of Al. Tube

$$= \mathbf{8.050 \text{ m}}$$

Therefore,

$$f_c = \frac{2.45}{8.05 \times 8.05} \times \sqrt{\frac{(65727 \times 10^6) \times (399.998 \times 10^{-8})}{7.678}}$$

$$= \mathbf{7.00 \text{ Hz}}$$

6.1.3 Ratio f_c/f :

$$f_c / f = \frac{7}{50}$$

$$= \mathbf{0.14}$$

From the f_c/f value, the factors V_σ and V_r are calculated as follows:

a) Ratio of dynamic and static main conductor stress

Refer page no 109 of IEC-865-1

for $0.04 < f_c/f < 0.8$

$$V_\sigma = 1$$

$$V_{\sigma 1} = 0.756 + 4.49 e^{-1.68\kappa} + 0.54 \log (f_c/f)$$

Where

$$\kappa = 1.6 \text{ for } \kappa > 1.6$$

$$V_{\sigma 1} = 0.756 + 4.49 e^{-1.68\kappa} + 0.54 \log (f_c/f)$$

$$= 0.756 + 4.49 \times \text{Exp} - (1.68 \times 1.6) + 0.54 \log (0.14)$$

$$= \mathbf{0.600}$$

$$V_{\sigma 2} = 1.0$$

Therefore,

$$V_\sigma = \mathbf{0.600}$$

b) Ratio of stress for main conductor with three phase auto-reclosing (V_r):-

Refer page no 109 of IEC-865-1

for $0.05 < f_c/f < 1.0$

$$V_r = 1.0 - 0.615 \log (f_c/f)$$

$$= 1.0 - 0.615 \log (0.14)$$

$$= \mathbf{1.525}$$